


Code: 74COB
Hartland | HARTLAND RANGE | Connection Units

Product Image



Wiring



Dimensions

Insert Type	1 gang 20A Cable Outlet
Insert Colour	Black
EAN13 Barcode	5017503241767
Commodity Code	85369095
Luckins TSI	398036155
ETIM Class	EC000450
Dimensions(Nominal)	Single: Height = 88.0mm Width = 88.0mm Depth = 5.0mm
Weight	124 GR
Fixing Hole Centres	Box Fixing = 60.3mm Grid Fixing = N/A
Minimum Wall Box Depth	35mm
Switched Poles	None
Current Rating	20 Amp
Voltage	220/250V AC
Maximum Load	20 Amp
Mains Frequency	50Hz
IP Rating	IP2XD
Contact Gap Minimum	None
Terminal Capacity 1	5 x1mm ²
Terminal Capacity 2	4x1.5mm ²
Terminal Capacity 3	2x2.5mm ²
Terminal Capacity 4	2x4mm ² Multi-strand
Earth Terminal Capacity 1	6x1mm ²
Earth Terminal Capacity 2	5 x 1.5mm2
Earth Terminal Capacity 3	3 x 2.5mm2
Earth Terminal Capacity 4	2 x 4mm2 Multi-strand
Earth Terminal Capacity 5	1 x 6mm2
Product Class 1	Must be earthed
Ambient Operating Temperature	-5° to +40°C
Recommended Location	Internal Use Only
Maximum Installation Altitude	2000m

DATASHEET

Hamilton®

making connections beautifully

Code: 74COB

Hartland | HARTLAND RANGE | Connection Units

Hamilton®


HARTLAND
CO
Cable outlet

Standard/Approval

BS 5733

Patents And Trade Marks

Hartland is a Registered Trade Mark No. 2344778



R Hamilton & Co Ltd, Unit 10 Carrick Business Centre,
4-5 Bonville Road, Brislington, Bristol, BS4 5NZ

T: +44 (0)1747 860088

E: info@hamilton-litestat.com | **W:** www.hamilton-litestat.com

(WEB)

All accessories are manufactured under an accredited BS EN ISO 9001:2015 Quality Management System. It is the policy of the company to improve products as part of our development programme. Therefore, we reserve the right to alter designs and dimensions without prior notice. Illustrations and diagrams are reproduced within the limitations of reproduction and printing process and are not binding. Due to manufacturing processes we cannot guarantee an exact colour match and shadings of certain finishes. This datasheet was generated on 19/05/2024 E&OE